

The Department of Energy has published updated energy efficiency metrics for central air conditioners and heat pumps. This publication reflects both the 1987 metric (SEER) and the 2023 metric (SEER2). Efficiency requirements are published at 10 C.F.R. 430.32(c). Please refer to www.AHRInet.org for more information about updated energy efficiency metrics.

U.S. Government

Federal law prohibits removal of this label before consumer purchase.


ENERGYGUIDE

Heat Pump
Cooling and Heating
Split System

MRCOOL
Model A-36-HP-C-230C




**Cooling
Efficiency Rating (SEER)***
16.00 - 18.00



Range of Similar Models

* Seasonal Energy Efficiency Ratio

**Heating
Efficiency Rating (HSPF)***
8.50 - 12.00



Range of Similar Models

* Heating Seasonal Performance Factor

For energy cost info, visit
productinfo.energy.gov

U.S. Government

Federal law prohibits removal of this label before consumer purchase.


ENERGYGUIDE



Heat Pump
Cooling and Heating
Split System

MRCOOL
Model A-36-HP-C-230C


Cooling
Efficiency Rating (SEER2)*
17.50 - 20.00



Range of Similar Models

* Seasonal Energy Efficiency Ratio

Heating
Efficiency Rating (HSPF2)*
7.80 - 8.70



Range of Similar Models

* Heating Seasonal Performance Factor

For energy cost info, visit
productinfo.energy.gov